


**SUMMARY OF RESULTS
OF TESTING CERTIFICATE 09150 / 04.12.2009**

NUMBER	09150	DATE	04 / 12 / 2009
---------------	--------------	-------------	-----------------------

Client' s data:	ETEM S.A. LIGHT METALS COMPANY 1, IROON POLYTEHNIU STR. GR 196 00 MAGOULA ATTIKIS - GREECE
Product description:	SINGLE SASH WINDOW WITH ONE FIXED ELEMENT TILT / TURN
Material:	ALUMINIUM
System :	E – 38 Thermo



1050 x 2130mm

Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	Class 4
Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	Specimen: Class 6A Sash: Class E1050
Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	Class C5

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



**SINOI PAPAPOPOULOU
TECHNICAL MANAGER**



**IOANNIS GKERTSOS
GENERAL MANAGER**

EXACT TRANSLATION FROM THE GREEK ORIGINAL