




## TEST CERTIFICATE SUMMARY OF TEST RESULTS

<b>NUMBER</b>	0316	<b>DATE</b>	29 /10 / 03
<b>Client' s data:</b>	<b>ETEM S.A.</b> <b>LIGHT METALS COMPANY</b> 1, IROON POLYTEHNIU STR. GR 190 18 MAGOULA ATTIKIS GREECE		
<b>Product description:</b>	<b>SINGLE SASH WINDOW</b> <b>OPENING / TILTING</b>		
<b>Material:</b>	<b>ALUMINIUM</b>		
<b>Window System :</b>	<b>E - 40</b>		



1356 x 1356 mm

<b>Air Permeability</b> <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	<b>Class 4</b>
<b>Watertightness</b> <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	<b>Class E1050</b>
<b>Resistance to Wind Load</b> <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	<b>Class C5</b>

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.

**MARIANTHI CHATZIANTONIOU**  
TECHNICAL MANAGER

**IOANNIS GKERTSOS**  
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL