


**SUMMARY OF RESULTS
OF TESTING CERTIFICATE 1103 / 24.01.2011**

NUMBER	1103	DATE	24 / 01 / 2011
---------------	-------------	-------------	-----------------------

Client' s data:	ETEM S.A. LIGHT METALS COMPANY 1, IROON POLYTEHNIU STR. GR 196 00 MAGOULA ATTIKIS - GREECE
Product description:	DOUBLE SASH BALCONY DOOR SLIDING
Material:	ALUMINIUM
System :	E – 52 Thermo



1720 x 2200mm

Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	Class 3
Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	External Rail: Class 2A Internal Rail: Class 3A
Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	Class C2 / B3

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



**SINOI PAPAPOPOULOU
LABORATORY MANAGER**



**IOANNIS GKERTSOS
GENERAL MANAGER**

EXACT TRANSLATION FROM THE GREEK ORIGINAL