


**SUMMARY OF RESULTS
OF TESTING CERTIFICATE 10128 / 07.01.2011**

NUMBER	10128	DATE	07 / 01 / 2011
---------------	--------------	-------------	-----------------------

Client' s data:	ETEM S.A. LIGHT METALS COMPANY 1, IROON POLYTEHNIU STR. GR 196 00 MAGOULA ATTIKIS - GREECE
Product description:	Double Sash Balcony Door Lift & Slide
Material:	ALUMINIUM
System :	E – 70 Thermo



Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	Class 3
Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	External Rail: Class 1A Internal Rail: Class 3A
Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	Class C4

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



SINOI PAPADOPOULOU
LABORATORY MANAGER



IOANNIS GKERTSOS
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL